Insulation

Dielectric boots



CLASE 2

17.5_{kV}
Maximum working voltage

Test voltage

30601 DB2

Dielectric boots

- Every boot tested to 20 kV (AC testing as standard, DC testing available on request).
- Leakage current less than 5 mA at 5 kV and less than 18 mA at 20 kV.
 Meets the requirements of ASTM 1117 (20 kV) and ASTM 2413.
- Blue vulcanized rubber sole for maximum grip 30% better than a conventional safety
- Slip resistance performance twice that required by SATRA TM144 standard.
- Two to three times the wear resistance of conventional soles.

Code	Ref.	Sizes
715155	DB2 T42	42
715160	DB2 T43	43
715165	DB2 T44	44
715170	DB2 T45	45

















