



545 SG-117

Pneumatic gauge tester

Before using dielectric gloves for live working, the EN 60903 and IEC 60903 standards recommend a visual inspection by inflating the gloves with air to detect any possible leakages.

The pneumatic tester is a pump system to optimise inflation and visual inspection, especially at the cuff level.
Class 0 and 00 only.

Code	Ref.
545120	SG-117