

sofamel

Product Technical Specifications

Mod. SG117 PNEUMATIC GAUGE TESTER

Á

Functionality

Pneumatic tester for checking the absence of pores in dielectric gloves. It is verified by swelling and subsequent immersion in water. Before each use of insulating gloves for electrical works, the EN-60903 standard recommends a quality checking of the gloves by a visual inspection. Overmore for the low voltage gloves, the standard advises to inflate gloves to detect any possible airleaks: the pneumatical tester is the equipment which permit a better inflation, and then a better checking Overmore for the low voltage gloves, the standard advises to inflate gloves to detect any possible air leaks: the pneumatical tester is the equipment which permit a better inflation, and then a better checking

Á

Product Features

Á

The pneumatic tester is a pump optimization system inflation and visual inspection, especially at the cuff level.

Only class 0 and 00

Weight: 504g

Öä ^} • 3 } • K H Á C H Á F G Á { Á



Datos sujetos a cambios
2017, Mayo 2

Versión: R2-7.2 COM01

Thomas Alva Edison, 16-17 - Pol. Industrial Plans d'Arau - 08787 La Pobla de Claramunt (Barcelona) - Spain
Tel. +34 93 808 79 80 - Info@sofamel.es
www.sofamel.com

© 2017 Sofamel SLU
Todos los derechos reservados.

Las especificaciones están sujetas a cambios sin previo aviso.