

# INSTRUCCIONES DE USO

# BANQUETAS AISLANTES

# ST/STE

## GUÍA PARA LA SELECCIÓN DE LA CLASE DE LA BANQUETA EN FUNCIÓN DE LA TENSIÓN NOMINAL DE UNA INSTALACIÓN:

La tensión máxima de uso recomendada para cada clase de banqueta está indicada en la siguiente tabla:

**TABLA E.1**  
Tensión máxima de uso

Clase	Tensión en corriente alterna V eficaces	Tensión en corriente continua V
0	1 000	1 500
1	7 500	11 250
2	17 000	25 500
3	26 500	39 750
4	36 000	54 000
5	45 000	67 500
6	66 000	99 000

### ALMACENAMIENTO

Deben ser almacenadas correctamente, para minimizar el riesgo de deterioro del aislamiento. Se debe evitar su almacenamiento en las proximidades de una fuente de calor, como por ejemplo los tubos de calefacción.

### VERIFICACIÓN PREVIA AL USO

Antes de su uso cada banqueta deberá ser verificada visualmente por el usuario. Si existiera alguna duda acerca de la seguridad de la banqueta, ésta deberá ser rechazada o verificada por una persona competente y sometida a ensayo si fuera necesario.

### PRECAUCIONES DURANTE EL USO

Las banquetas no deberán ser expuestas innecesariamente al calor o a la luz, y se deberá evitar el contacto con sustancias peligrasas, tales como aceites o ácidos.

### INSPECCIONES VISUALES PERIÓDICAS

Es recomendable que la banqueta sea sometida periódicamente a una inspección visual por parte de personal competente.

# INSTRUCTIONS FOR USE

# INSULATING STOOL

# ST/STE

## GUIDE FOR SELECTING THE CLASS OF STOOL BASED ON THE NOMINAL VOLTAGE OF A SYSTEM:

The maximum recommended usage voltage for each stool class is indicated in the following table:

**TABLE E.1**  
Maximum usage voltage

Class	AC voltage RMS (Root Mean Square) V	DC voltage V
0	1 000	1 500
1	7 500	11 250
2	17 000	25 500
3	26 500	39 750
4	36 000	54 000
5	45 000	67 500
6	66 000	99 000

### STORAGE

They must be stored properly to minimize the risk of insulation deterioration. Storage near a heat source, such as heating pipes, should be avoided.

### PRE-USE VERIFICATION

Before use, each stool must be visually inspected by the user. If there is any doubt about the safety of the stool, it should be rejected or inspected by a competent person and tested if necessary.

### PRECAUTIONS DURING USE

The stools should not be exposed unnecessarily to heat or light, and contact with hazardous substances, such as oils or acids, should be avoided.

### PERIODIC VISUAL INSPECTIONS

It is recommended that the stool be periodically inspected visually by competent personnel.